

This information was generated by the HP KEYMARK database on 13 Oct 2021

# Model: MHC-V14W/D2RN8

Configure model			
Model name	MHC-V14W/D2RN8		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

# Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	14.10 kW	14.20 kW	
El input	3.05 kW	5.09 kW	
СОР	4.63	2.79	

## **Average Climate**

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



This information was generated by the HP KEYMARK database on 13 Oct 2021

### EN 14825

EIV 2-025			
	Low temperature	Medium temperature	
$\eta_{s}$	168 %	128 %	
Prated	14.00 kW	14.00 kW	
SCOP	4.27	3.26	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	12.47 kW	12.18 kW	
COP Tj = -7°C	2.84	2.05	
Cdh Tj = -7 °C	0.90	0.90	
Pdh Tj = +2°C	7.48 kW	7.84 kW	
COP Tj = +2°C	4.19	3.18	
Cdh Tj = +2 °C	0.90	0.90	
Pdh Tj = +7°C	5.04 kW	5.21 kW	
$COP Tj = +7^{\circ}C$	5.99	4.29	
Cdh Tj = +7 °C	0.90	0.90	
Pdh Tj = 12°C	2.23 kW	2.57 kW	
COP Tj = 12°C	5.30	5.14	
Cdh Tj = +12 °C	0.90	0.90	
Pdh Tj = Tbiv	12.47 kW	12.18 kW	
COP Tj = Tbiv	2.84	2.05	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Sound power level outdoor

### This information was generated by the HP KEYMARK database on 13 Oct 2021

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.72 kW	11.68 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	1.74
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	26 W	26 W
PSB	9 W	9 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	2.10 kW
Annual energy consumption Qhe	6819 kWh	8724 kWh

# EN 12102-1 Low temperature Medium temperature Sound power level indoor dB(A) dB(A)

71 dB(A)

71 dB(A)