

Model: MHA-V14W/D2N8-B+HB-A160/C****GN8-B

Configure model	
Model name	MHA-V14W/D2N8-B+HB-A160/C****GN8-B
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.50 kW	13.80 kW
EI input	3.09 kW	4.60 kW
COP	4.70	3.00

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	13.73 kW	12.08 kW
SCOP	4.72	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.14 kW	10.69 kW
COP Tj = -7°C	2.79	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.95 kW	6.86 kW
COP Tj = +2°C	4.52	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.20 kW	4.64 kW
COP Tj = +7°C	6.68	4.66
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 25 Dec 2021

Pdh Tj = 12°C	3.76 kW	3.32 kW
COP Tj = 12°C	8.52	6.13
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.14 kW	10.69 kW
COP Tj = Tbiv	2.79	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.48 kW	9.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.76
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.91 kW
Annual energy consumption Qhe	6012 kWh	7202 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	260 %	175 %
Prated	12.11 kW	14.17 kW
SCOP	6.63	4.45
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.04 kW	13.05 kW
COP Tj = +2°C	3.44	2.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.78 kW	9.11 kW
COP Tj = +7°C	5.84	3.89
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	8.25	5.90
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.78 kW	9.11 kW
COP Tj = Tbiv	5.84	3.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.04 kW	13.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.44	2.20
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

This information was generated by the HP KEYMARK database on 25 Dec 2021

WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.07 kW	1.13 kW
Annual energy consumption Qhe	2457 kWh	4258 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	119 %
Prated	12.64 kW	10.97 kW
SCOP	4.07	3.05
Tbiv	-15 °C	-15 °C

This information was generated by the HP KEYMARK database on 25 Dec 2021

TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.97 kW	6.89 kW
COP Tj = -7°C	3.44	2.66
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.05 kW	4.32 kW
COP Tj = +2°C	4.92	3.66
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.16 kW	3.06 kW
COP Tj = +7°C	6.11	4.72
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.58 kW	3.33 kW
COP Tj = 12°C	7.82	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.31 kW	8.95 kW
COP Tj = Tbiv	2.53	1.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W

This information was generated by the HP KEYMARK database on 25 Dec 2021

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.07 kW	6.77 kW
Annual energy consumption Qhe	7667 kWh	8866 kWh
Pdh Tj = -15°C (if TOL<-20°C)	10.31	8.95
COP Tj = -15°C (if TOL<-20°C)	2.53	1.79
Cdh Tj = -15 °C	0.90	0.90