

Subtype M thermal A HT Series 4 6 kW

Certificate Holder	GD Midea Heating & Ventilating Equipment Co., Ltd.
Address	Penglai Industry Road
ZIP	528311
City	Beijiao, Shunde, Foshan
Country	CN
Certification Body	ICIM S.p.A.
Subtype title	M thermal A HT Series 4 6 kW
Registration number	ICIM-PDC-000197
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	0.7 kg
Certification Date	08.09.2023
Testing basis	V12

Model MHC-V4WD2N7-***

Model name	MHC-V4WD2N7-***
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Colder, Warmer
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.5 kW	4.6 kW
El input	0.87 kW	1.44 kW
COP	5.15	3.20

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	199 %	148 %
Prated	5.00 kW	4.90 kW
SCOP	5.07	3.79
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.45 kW	4.36 kW
COP Tj = -7°C	3.39	2.60
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	2.75 kW	2.65 kW
COP Tj = +2°C	5.04	3.75
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.72 kW	2.57 kW
COP Tj = +7°C	6.72	4.97

Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.14 kW	3.04 kW
COP Tj = 12°C	8.52	6.55
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.45 kW	4.36 kW
COP Tj = Tbiv	3.39	2.60
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.00 kW	4.36 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.92	2.08
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	75 °C	75 °C
Poff	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.57 kW
Annual energy consumption Qhe	2034 kWh	2668 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	158 %	124 %
Prated	5.0 kW	4.3 kW
SCOP	4.03	3.18
Tbiv	-15.00 °C	-15.00 °C
TOL	-22.00 °C	-22.00 °C
Pdh Tj = -7°C	3.02 kW	2.60 kW
COP Tj = -7°C	3.54	2.75
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.20 kW	2.11 kW
COP Tj = +2°C	4.89	3.91
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.61 kW	2.47 kW
COP Tj = +7°C	6.60	5.04
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.86 kW	2.77 kW
COP Tj = 12°C	7.03	6.14
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.08 kW	3.51 kW
COP Tj = Tbiv	2.56	2.11

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.40 kW	2.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.98	1.43
WTOL	75.00 °C	75.00 °C
Poff	9.00 W	9.00 W
PTO	14 W	14 W
PSB	9.00 W	9.00 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.34 kW
Annual energy consumption Qhe	3056.00 kWh	3328.00 kWh
Pdh Tj = -15°C (if TOL	4.08	3.51
COP Tj = -15°C (if TOL	2.56	2.11
Cdh Tj = -15 °C	0.9	0.9

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	235.00 %	170.00 %
Prated	4.6 kW	4.7 kW
SCOP	5.97	4.34
Tbiv	7.00 °C	7.00 °C
TOL	2.00 °C	2.00 °C
Pdh Tj = +2°C	4.47 kW	4.61 kW
COP Tj = +2°C	4.08	2.69
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.97 kW	3.08 kW
COP Tj = +7°C	5.78	3.91
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.05 kW	2.94 kW
COP Tj = 12°C	7.64	5.85
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	2.97 kW	3.08 kW
COP Tj = Tbiv	5.78	3.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.47 kW	4.61 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.08	2.69
WTOL	75.00 °C	75.00 °C
Poff	9.00 W	9.00 W
PTO	14.00 W	14.00 W
PSB	9 W	9 W

PCK	0.00 W	0.00 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.13 kW	0.09 kW
Annual energy consumption Qhe	1024.00 kWh	1446.00 kWh